

**U.S. DEPARTMENT OF ENERGY  
OFFICE OF CIVILIAN RADIOACTIVE WASTE MANAGEMENT**

**NUCLEAR WASTE TECHNICAL REVIEW BOARD  
PANEL ON THE ENGINEERED BARRIER SYSTEM**

**SUBJECT: EFFECTS OF THERMAL  
LOADING ON ENGINEERED  
BARRIER SYSTEM**

**PRESENTER: RICHARD P. MORISSETTE**

**PRESENTER'S TITLE  
AND ORGANIZATION: SENIOR ENGINEER,  
SCIENCE APPLICATIONS INTERNATIONAL CORPORATION  
LAS VEGAS, NEVADA**

**PRESENTER'S  
TELEPHONE NUMBER: (702) 794-7783**

**AUGUSTA, GA  
FEBRUARY 10, 1992**

# Outline

- **Prior meetings where thermal loading discussed**
- **SCP thermal goals**
- **Near-field & far-field temperatures for various thermal loads**
- **Effects of thermal loading on Engineered Barrier System**

# NWTRB Meetings on Thermal Loading

- **March 1990 - Development of Design Requirements for Repository and Waste Package**
  - **Influence of thermally induced effects and thermal design approach**
- **October 1991 - Evaluation of Ranges of Thermal Loading for HLW Disposal in Geologic Repositories**
  - **Current reference thermal load for a repository in Yucca Mountain**
  - **Thermal loading basis of other repositories**
  - **Issues, considerations, and implication of lower and higher thermal loads**

# SCP Thermal Goals

*page 19 x right*

<u>Performance Measure</u>	<u>Goal</u>
Cladding Integrity	Container Centerline Borehole Wall T < 350 °C T < 275 °C
Near-Field Rock Mass Integrity	One Meter from Borehole T < 200 °C
Access Drift Wall Temperature	T <sub>wall</sub> < 50 °C for 50 years
Temperature Change in Adjacent Strata	T <sub>Sw2</sub> - T <sub>Sw3</sub> Interface T < 115 °C
Surface Environment	Temperature Change < 6 °C
Limit Corrosiveness of Canister Environment	Maximize Time Spent Above Boiling in Borehole Environment

# Bases for 200 °C Temperature Limit at One Meter from Borehole

*x copy p 21*

- **Requirement**
  - **Reduce potential for borehole collapse**
- **Bases**
  - **Welded tuff phase change around 200 °C to 250 °C**
  - **5 mm radial displacement predicted at borehole wall indicates insignificant rock movement in borehole**
- **Need for further evaluation**
  - **True magnitude of phase change**
  - **Actual stress/strain state at borehole surface and predict potential for borehole failure**

# Peak Fuel Cladding Temperature

p 2 2

- **Creep/stress rupture is dependent on time-at-temperature/environment**
- **1986 PNL study <sup>(1)</sup> indicated a 380 °C max. Zircaloy cladding temperature for long-term dry storage in an inert environment**
- **1990 LLNL study <sup>(2)</sup> indicated 300-340 °C max. Zircaloy cladding temperature for 1000-year life in dry environment** *1000 YRS*

Ref: (1) Chin, B. A., et al., PNL-5998, Deformation and Fracture Map Methodology for Predicting Cladding Behavior During Dry Storage, September 1986

(2) Chin, B. A., et al., UCRL-100212, Zircaloy Cladding Degradation under Repository Conditions, December 1990

5

# Outline

- **Prior meetings where thermal loading discussed**
- **SCP thermal goals**
- **Near-field & far-field temperatures for various thermal loads**
- **Effects of thermal loading on Engineered Barrier System**

# Repository Design Scenarios

Feature	SCP-CDR Design	Modified Design (SNL)	Drift Emplacment (LLNL)
<b>Orientation</b>	<b>Vertical/Horizontal</b>	<b>Vertical</b>	<b>Drift</b>
<b>Available Panels</b>	<b>17</b>	<b>15</b>	<b>17</b>
<b>Start Date</b>	<b>1998</b>	<b>2010</b>	<b>2010</b>
<b>Receipt Schedule</b>	<b>FIFO</b>	<b>Levelized</b>	<b>Levelized</b>
<b>Treatment of DHLW</b>	<b>Commingled</b>	<b>Segregated</b>	<b>Commingled</b>
<b>DHLW Initial Power Output</b>	<b>0.2 to 0.4 kW/ Container</b>	<b>0.2 kW/Container</b>	<b>0.2 kW/Container</b>
<b>SF Container Configuration</b>	<b>Consolidated</b>	<b>Intact Hybrid (4 BWR, 3 PWR)</b>	<b>Intact (5-26 PWR)</b>
<b># of SF Containers</b>	<b>~25,000</b>	<b>~31,000</b>	<b>~7,000 (26 PWR)</b>
<b>Average SF Age</b>	<b>10 years</b>	<b>30-90 years</b>	<b>30-60 years</b>
<b>Average SF Initial Power Output</b>	<b>3 kW/Container</b>	<b>1.5-0.66 kW/ Container</b>	<b>1.6-5 kW/ Container</b>
<b>Design-Basis APD</b>	<b>57 kW/acre</b>	<b>80-22 kW/acre</b>	<b>20-114 kW/acre</b>
<b>Drift Spacing</b>	<b>126 ft</b>	<b>53 ft</b>	<b>126 ft</b>
<b>Container Spacing</b>	<b>15 ft</b>	<b>Variable</b>	<b>End to End</b>
<b>Standoffs from Mains</b>	<b>200 ft</b>	<b>150 ft</b>	<b>TBD</b>



# Models Used for Thermal Loading Studies

- **Conduction model (SNL)**
  - **3-D linear superposition of heat generators**
  - **Stepped emplacement of SF**
  - **Complete geometric model**
  - **Scaling of emplacement densities**
  - **Conduction only**
- **Two-phase hydrothermal models (LLNL)**
  - **Repository-scale model using finite disk heat source**
  - **Drift-scale model using infinite repository with axial heat source**
  - **Instantaneous thermal load**
  - **V-TOUGH code with conduction, convection, radiation, boiling and condensation**

# Normalized Area Required for Repository as a Function of Initial APD and Spent Fuel Age\*

	20 kW/acre	36 kW/acre	57 kW/acre	80 kW/acre	100 kW/acre
<b>10-year-old fuel</b>	<b>2.85</b>	<b>1.57</b>	<b>1.00</b>	<b>0.71</b>	<b>0.57</b>
<b>30-year-old-fuel</b>	<b>1.81</b>	<b>1.00</b>	<b>0.64</b>	<b>0.45</b>	<b>0.36</b>
<b>60-year-old fuel</b>	<b>1.14</b>	<b>0.63</b>	<b>0.40</b>	<b>0.29</b>	<b>0.23</b>
<b>100-year-old fuel</b>	<b>0.73</b>	<b>0.40</b>	<b>0.25</b>	<b>0.18</b>	<b>0.15</b>

\* Areas are divided by area for the reference SCP-CDR design

# Modified SCP-CDR Design Peak Temperatures\*

<b>Design-Basis APD (kW/acre)</b>	<b>80</b>	<b>57</b>	<b>48</b>	<b>30</b>	<b>22</b>
<b>Average Waste Age (years)</b>	<b>30</b>	<b>30</b>	<b>30</b>	<b>60</b>	<b>90</b>
<b>Average Initial Power Output (kW/container)</b>	<b>1.52</b>	<b>1.52</b>	<b>1.52</b>	<b>0.95</b>	<b>0.66</b>
<b>Location</b>	<b>Temperature (°C)</b>				
<b>Borehole Wall</b>	<b>170</b>	<b>147</b>	<b>132</b>	<b>103</b>	<b>95</b>
<b>1-meter Radially</b>	<b>158</b>	<b>135</b>	<b>118</b>	<b>97</b>	<b>91</b>
<b>Depth Below waste</b>					
<b>50 m</b>	<b>107</b>	<b>94</b>	<b>86</b>	<b>77</b>	<b>74</b>
<b>70 m</b>	<b>100</b>	<b>89</b>	<b>81</b>	<b>74</b>	<b>71</b>
<b>90 m</b>	<b>94</b>	<b>84</b>	<b>77</b>	<b>60</b>	<b>59</b>
<b>Time to Boiling Front Coalescence Betw. Drift (yrs)</b>	<b>12</b>	<b>19</b>	<b>31</b>	<b>n/a</b>	<b>n/a</b>

\* Source: E. Ryder, SNL (Conduction model)

## Drift Emplacement Design Peak Temperatures and Extent/Saturation of Dry Out Zone\*

<b>Design-Basis APD (kW/acre)</b>	<b>114</b>	<b>100</b>	<b>80</b>	<b>57</b>	<b>36</b>
<b>Average Waste Age (years)</b>	<b>60</b>	<b>30</b>	<b>30</b>	<b>30</b>	<b>30</b>
	<b>Temperature (°C)</b>				
<b>Drift Wall</b>	<b>277</b>	<b>180</b>	<b>150</b>	<b>123</b>	<b>90</b>
<b>Waste Package Wall</b>	<b>283</b>	<b>202</b>	<b>174</b>	<b>137</b>	<b>102</b>
<b>60 m Below Waste</b>	<b>212</b>	<b>136</b>	<b>115</b>	<b>94</b>	<b>71</b>
	<b>Dry Out Zone (m)</b>				
<b>Above Waste @ 1000 years</b>	<b>205</b>	<b>130</b>	<b>104</b>	<b>50</b>	<b>0</b>
<b>Below Waste @ 1000 years</b>	<b>157</b>	<b>115</b>	<b>106</b>	<b>50</b>	<b>0</b>
<b>Above Waste @ 5000 years</b>	<b>190</b>	<b>120</b>	<b>96</b>	<b>40</b>	<b>0</b>
<b>Below Waste @ 5000 years</b>	<b>166</b>	<b>166</b>	<b>166</b>	<b>50</b>	<b>0</b>
	<b>Rock Saturation (%)</b>				
<b>Drift Wall @ 1000 years</b>	<b>0</b>	<b>0</b>	<b>4</b>	<b>11</b>	<b>66</b>
<b>Drift Wall @ 10,000 years</b>	<b>0</b>	<b>9</b>	<b>12</b>	<b>30</b>	<b>67</b>
<b>Drift Wall @ 100,000 years</b>	<b>15</b>	<b>46</b>	<b>55</b>	<b>66</b>	<b>67</b>

\* Source: T. Buscheck, LLNL (Hydro-thermal model)

# Outline

- **Prior meetings where thermal loading discussed**
- **SCP thermal goals**
- **Near-field & far-field temperatures for various thermal loads**
- **Effects of thermal loading on Engineered Barrier System**

# Effects of Thermal Loading on EBS

- **Effects on EBS Environment**
  - **Geomechanical**
  - **Geochemical**
  - **Hydrogeological**
- **Effects on EBS components**
  - **Containers**
  - **Waste form**
  - **Other EBS Components**

# Potential Geomechanical Effects of Thermal Loading

- **Rock mass**
  - **Rock Mass modulus and stress changes with temperature/time**
  - **Stability of usable areas changes due to changes in modulus and stress**
- **Fractures**
  - **Open fractures in regions of tensional stress**
  - **Close fractures in region of compressive stress**
  - **Fracture permeability changes due to changes in fracture size**

# **Resolution of Uncertainties Due to Geomechanical Effects**

- **Existing scientific plans address uncertainties associated with geomechanical effects**
- **Thermal loads must be incorporated into the design**
- **Design methodology is independent of degree of thermal load**
- **Available experience in underground excavations with comparable stress magnitudes will be considered**
- **Joint slip or fracture propagation will be evaluated through analysis and testing**



# Potential Geochemical Effects of Thermal Loading

- **Dissolution/precipitation (under aqueous conditions)**
  - Increase fracture healing
  - Increase dissolution/precipitation in fracture networks
  - Change silica activities which influence the development of assemblages
  - Form additional zeolites and clays
  - Alter permeability and porosity
  - Potential for oxidation of mineral phases
- **Cation exchange**
  - Alter sorption capability
- **Radiolysis effects**

# **Resolution of Uncertainties Due to Geochemical Effects**

- **Existing scientific plans address uncertainties associated with geochemical processes**
- **Geochemistry and hydrology is being integrated**
- **Elements of a near-field geochemistry program required to resolve issues:**
  - **Modeling applications**
  - **Experimental-rock/water interaction**
  - **Thermodynamic and kinetic data acquisition and development**
  - **Model development**
  - **Natural analogue studies**

# Potential Hydrogeologic Effects of Thermal Loading

- **Fracture flow**
  - Increase matrix imbibition
  - Alter flow and transport properties
  - Attenuate episodic fracture flow
  - Promote rapid condensate drainage around and below waste
- **Rock dry out/water availability**
  - Increase boiling and water transport away from EBS
  - Increase extent of rock dry-out
  - Produce a dry steam environment

# **Resolution of Uncertainties Due to Hydrogeologic Effects**

- **Thermal hydrogeologic coupled models will address range of thermal loads**
- **Hydrogeologic uncertainties are reduced for high thermal loads**
- **Testing at higher temperature conditions provides better experimental basis for model validation**
- **Site characterization testing will support model validation**

# Potential Effects of Thermal Loading on Container Degradation

- Localized corrosion
- Microbial corrosion
- Environmentally accelerated cracking
- Aqueous corrosion
- Hydrogen effects
- Mineral deposition
- Radiolysis

- General oxidation
- Stress relieving
- Long-term aging effects
- Mineral deposition
- Radiolysis

- Microstructural changes
- Accelerated oxidation

Boiling  
Point

300 - 500 °C  
(Material Dependent)

Temperature

# Potential Effects of Thermal Loading on Waste Form Degradation

- **No glass devitrification below 450 °C**
- **Under wet conditions glass vapor hydration rate increases with temperature**
- **Under wet conditions SF pellet and glass dissolution rate increases with temperature**
- **SF pellet oxidation rate increases with temperature**
- **Dissolution rate dependent on environmental history of waste form prior to liquid contact**
- **Zircaloy fuel rod cladding degradation reduced in the 100 - 300°C temperature range**

# **Resolution of EBS Component Uncertainties Due to Effects of Thermal Loading**

- **Long-term material testing under range of anticipated environments is necessary**
- **Characterization of post-emplacment waste-form behavior will continue**
- **Studies will be performed that will consider waste-form behavior and containment design under range of anticipated environment**
- **Performance confirmation testing through retrievability period will reduce remaining uncertainties**

# Summary

- **DOE continues to analyze the range of thermal loads and is developing thermal management scenarios**
- **Selection of a repository thermal management strategy will consider impacts on the total civilian radioactive waste management system (CRWMS)**
- **The CRWMS M&O has initiated a study of these system implications**



RICHARD P. MORISSETTE

EDUCATION: M.B.A., San Diego State University, (1979)  
B.S., Mechanical/Nuclear Engineer,  
San Jose State Univ., (1961)

EXPERIENCE:

5 YEARS WITH SAIC-YUCCA MOUNTAIN PROJECT: Currently a Senior Engineer in the Field Test Facility Support Department providing technical and management support to the Yucca Mountain Project Office (YMPO). Provided integration of the U.S. waste package program and repository program ongoing at Lawrence Livermore National Laboratory and Sandia National Laboratory. Provided input to and review of the program budget and schedule, design and testing activities, and materials development. Prepared and maintained management, task plans, and design interfaces between the repository and the waste package.

20 YEARS WITH GENERAL ATOMICS: As a nuclear waste and fuel engineer, developed characterization data for the Oak Ridge National Laboratory on spent fuel from gas-cooled and experimental reactors. Developed a universal canister concept for handling spent fuel from light water reactors to MRS to repository. Prepared the initial evaluation of an MRS including initial siting and transportation evaluations, system objectives, functional requirements and system descriptions, and concept evaluations. Developed business strategies involving uranium and nuclear fuel. Participated in Fort St. Vrain Nuclear Generating Station fuel and core component design, fabrication, and initial core loading and was responsible for planning and coordinating the total fuel cycle. Lead Engineer on the fuel test program conducted in Peach Bottom HTGR.

5 YEARS WITH GENERAL ELECTRIC: As a Design and Test Engineer at Vallecitos Atomic Laboratory, was involved in all phases of nuclear facility operation. Activities included design and safety analysis of in-reactor fuel testing systems, underwater inspection and disassembly equipment, reactor coolant cleanup systems, reactor fuel and core components. A Licensed Reactor Operator at the General Electric Test Reactor and Radiation Monitor at Vallecitos Boiling Water Reactor. Coordinated hot cell repair of reactor equipment and participated in reactor reload operations, outage maintenance, and spent fuel handling and shipping.