

Repository Thermal Management

Presented to:

Nuclear Waste Technical Review Board


Presented by:

Dr. James A. Blink

Design Basis Models Manager, Engineer and Integration
CRWMS Management and Operating Contractor

(702) 295-4371

October 22, 1997



U.S. Department of Energy
Office of Civilian Radioactive
Waste Management

Agenda

- **The MGDS thermal goals**
- **Comparison of thermal goals and design performance**
- **Extension to overall MGDS performance**
- **Influence of ventilation on thermal behavior**
- **Options to decrease clad temperature (to compensate for other components that heat it)**
- **Summary**

Thermal Loading Assumptions - 1

- **High range (80-100 MTU/acre)**
 - **Rationale: Accommodates 70,000 MTU in characterized area, has projected acceptable performance, has reduced footprint and cost**
 - **Risk Mitigation: Alternate Areal Mass Loadings (AMLs) (e.g. 36 and 115 MTU/acre)**
 - **Controlled Design Assumption: Key 019**
- **WP spacing set by its MTU (“point loading”)**
 - **DHLWPs in gaps between large Waste Packages**
 - **Drift spacing maximized within AML and temperature limit constraints, WP spacing minimized, reduced costs**
 - **CDA Key 077**

Thermal Loading Assumptions - 2

- **Zeolite temperature limit**
 - **< 90°C at 170 m below repository horizon**
 - **Sets AML (85 MTU/acre)**
 - **Rationale: Maintain sorption capability; do not dehydrate clinoptilolite or convert it to analcime**
 - **CDA Design Concept SubSurface (DCSS) 025**
- **Drift wall temperature limit**
 - **< 200°C**
 - **For the reference drift diameter, sets drift spacing (28 m) and hence WP spacing**
 - **Rationale: Limit thermal stress. Stay below cristobalite phase change (225-230°C)**
 - **CDA DCSS 023**

Thermal Loading Assumptions - 3


- **Cladding temperature limit**
 - **< 350°C**
 - **Rationale:**
 - » **One to two orders of magnitude peak dose rate reduction for cladding credit**
 - » **Intact Zircalloy cladding is > 98% of received waste (1.15% stainless steel clad, < 0.1% perforated Zircalloy)**
 - » **Intact Zircalloy cladding is extremely resistant to corrosion, limiting radionuclide mobilization**
 - » **Radionuclide mobilization requires two independent failures:**
 - **Perforation (creep rupture) due to rod pressure rise**
 - **Early WP failure (< 150 yr, waste > 200°C), free oxygen will oxidize UO₂ thru clad perforation, consequent swelling will unzip clad [drift atmosphere may be pure water vapor at that time]**
 - **CDA DCWP 001**

Thermal Loading Assumptions - 4

- **Other temperature limits**
 - **Shafts/ramps: $< 35^{\circ}\text{C}$ (ignoring ventilation)**
 - » CDA DCSS 023
 - **Main drifts: $< 50^{\circ}\text{C}$**
 - » CDA DCSS 023
 - **PTn $< 115^{\circ}\text{C}$**
 - » CDA DCSS 031
 - **Surface temperature rise $< 2^{\circ}\text{C}$**
 - » CDA EBDRD 3.7.G.4


Design Limits vs Calculated Temperatures

83 MTU/acre, Point Load, No Backfill, 6.2 mm/yr Ambient Flux




22.5 m drift spacing

Notional Dependence of Dose Rate on Thermal Loading



Calculated WP Surface Temperatures


83 MTU/acre, Point Load, No Backfill, 6.2 mm/yr Ambient Flux



22.5 m drift spacing

Calculated WP Surface Relative Humidity


83 MTU/acre, Point Load, No Backfill, 6.2 mm/yr Ambient Flux



22.5 m drift spacing

Reference Design WP Environment vs Corrosion Susceptibility

83 MTU/acre, Point Load, No Backfill, 6 mm/yr Ambient Flux



Ventilation effects on WP and Drift Wall Temperatures


- Currently, ventilation is 0.1 m³/s after the drift is full, as a preclosure radiological control measure. This removes some water, but does not limit the temperature
- The ESF ventilation system removes 200 mm/yr of flux, based on the drift surface area
- Repository Design has done analyses of time required to “blast cool” the drift for reentry, as a function of ventilation rate
- UNR recently completed an analysis for the NWTRB that included long term natural convection in both *open* and *closed* repositories
- Long term ventilation has two potential benefits: temperature control and moisture removal

Preclosure Repository Ventilation

Ventilation Rate, m³/s

	0.1	0.6	1.0	2.0	5.0	10
Peak Air Temperature, ° C	141	120	107	83	56	43
Peak Drift Wall Temperature, ° C	144	128	117	95	67	51
100 yr Heat Removed, %	8%	38%	52%	67%	79%	83%

Natural Ventilation of a Closed Repository (UNR Report to NWTRB)



NOT TO SCALE

Options to Decrease Clad Temperature

- **Thicken the aluminum shunts in the basket**
- **Thermal blending in the WP (to reduce peak thermal power from the current 18 kW limit)**
- **Storage underground in a strongly ventilated drift until heat output falls to the desired level**
- **Increase WP spacing (and reduce drift spacing)**
- **Line load - space WPs very closely (< 1 m gaps) to use low output WPs as “fins” for high output WPs.**
- **Preclosure ventilation up to ten times the current design**

Thermal Tradeoffs Provide Flexibility

- **The reference VA design is expected to meet DOE's guidance**
- **Design features such as ceramic coatings, backfill, and drip shields have the potential to significantly reduce peak dose rates at the accessible environment, but they tend to increase cladding temperatures**
- **Methods have been identified to compensate for increased cladding temperatures from these design features**